

RFP2122 – Security 001 All Responses to Written Inquiries

1: To ensure we are all bidding on the same scope, how many cameras do you need and in what locations?

Minimums:

- Pelee – 1 (Records Room), 2 on Main Entrance (1 interior, 1 exterior), 2 on visitation entrance (1 interior 1 exterior), 2 upstairs (1 for each stairwell - interior)
- Maitland – 2 Reception (1 interior, 1 exterior), 1 stairwell (interior), 1 Training Space (view of conf/brd & storage spaces)
- OSC – 3 reception 1st floor (2 interior, 1 exterior), 1 1st floor stairwell, 1 – back of café facing exit, 1 – facing DeMarc Room, 2-2nd floor lobby facing each entrance, 1 for Drug Testing Entrance, 1 on fob access door (Drug Testing area), 1 – 2nd floor stairwell

2: To ensure we are all bidding on the same scope, how many doors do you need access controlled?

- Pelee – 10 access controls
- Maitland – Reception, server room, training area, stairwell
- OSC – 8 access controls

3: Can you provide an inventory of the existing camera and access control system?

- Pelee – 2 cameras with 6 access points
- Maitland – new site
- OSC – new site

4: Is continuous recording for 60 days required?

- 60-day requirement is not necessary if equipment/product is sound/comprehensive.

5: In the event of a down camera is there a minimum SLA time for a new replacement, such as overnight?

- Two (2) business days

6: Is there a minimum hardware warranty required?

- At least One (1) year

7: Are automatic firmware and software updates required?

- Automatic – No
- Knowledge base of available updates - Yes

8: Does data need to be encrypted at rest and in transit?

- Yes

9: To clarify the language in the RFP, both the Camera and Access Control system should be on the same platform and completely integrated without the use of any third-party software. A single pane of glass approach?

- Yes, we prefer single pane approach

10: In order to budget for the RFID cards or fobs, how many users will be in the access control system?

- Approximately 500

11: Are you able to clarify the following statement. "It is the intent of the agency to award the bid to Primary vendor. In the event that a Primary and Secondary vendor are awarded, the primary vendor will receive first opportunity to quote projects and schedule. The secondary vendor will be given an opportunity if the primary vendor is unable to meet the requirements or timeline of the project or is currently involved in a project. Project timelines will be set for each project when quotes are submitted."

Are we bidding for this project as a whole? Or in parts? What, if any situation would result in the project being awarded to two vendors?

- We are bidding project as a whole, nothing foreseeable.

12: This project and its associated components will require vendors to be appropriately licensed in the state of Florida as either ES or EC electrical contractors. Will be buyer be verifying this status for all bidders?

- Yes

13: Are you able to clarify the following statement "It is our intent that multiple purchase orders may be issued as a result of this bid" Does this mean to be separate PO's for this project as phases over time or separate PO's for other potential further projects?

- Yes, separate funding streams for the sites, and for future projects

14: Please clarify the accepted certifications for the project manager as per this statement, Would industry experience and previous project oversight of similar size be acceptable along with references? "Contractor must provide "Project Management" (PM) staff to coordinate with other trades and contractors on projects. Include documentation of Security Project Management or NICET II certification at a minimum.

- Industry experience and previous oversight would be acceptable for Project Management criteria.

15: Is US-Based technical support required?

- Preferred, not required.

16: Are there any products that cannot be used?

- Any product banned by FCC for Government use. Including HIK Vision, Dhuazte, etc.

17: Please confirm if free wired cabling is acceptable for this project?

- It is not acceptable. All hardwired, not WiFi or Bluetooth

18: Can you please confirm that the EF License is above the NICET II certification?

- Yes